



NOTES:

- 1) RCD: STANDS FOR REMOTE CONTROL DEVICE BY CUSTOMER.
- 2) X2 TERMINAL GROUNDED AS STANDARD, REMOVE GROUND IF NOT REQUIRED
- 3) DO NOT WIRE CONTROL CIRCUIT TO LINE SIDE OF CONTACTOR WHEN COIL VOLTAGE IS 120V OR LESS
- 4) [] : FOR MULTIFUNCTION TERMINAL NUMBERS.

11	ADDED POWER ON PILOT LIGHT.	3-23-2015	CG
REV	DESCRIPTION	DATE	APP'D
DESIGNED EAP	FVNR MAGNETIC STARTER SINGLE PHASE FOR D SERIES PILOT DEVICES TYPICAL CONTROL CIRCUITS		
DRAWN EAP			
APPROVED PAB			
DATE 12-17-87			
DWG. NO.	CBT WS-101-11	SERIES	100